



Number	97805/01	Replaces	Q96/058
Issued	01/04/2020	Scope	AR 5
Contract number	Q96/058	Page	1-2

Product Certificate

## Copper tubes

Based on pre-certification tests as well as periodic inspections by Kiwa Nederland B.V., the products referred to in this certificate and marked with the GASTEC QA mark, supplied by

## Mueller Europe Limited

may, on delivery, be relied upon to comply with the GASTEC QA Approval Requirements 5, for copper tubes dated September 2019.

Ron Scheepers  
Kiwa

This certificate is issued by Kiwa Nederland B.V. in conjunction with the KIWA regulations for Certification 2017.

This certificate consists of 2 pages.  
Publication of the certificate is allowed.

Kiwa Nederland B.V.  
Sir. Winston Churchillaan 273  
P.O. Box 70  
2280 AB RIJSWIJK  
The Netherlands  
Tel.+31 88 998 4400  
info@kiwa.nl  
www.kiwa.nl

**supplier**  
**Mueller Europe Ltd**  
Oxford Street  
Bilston  
West Midlands WV14 7DS  
United Kingdom

[www.muellereurope.com](http://www.muellereurope.com)

T +44 1902 499 700  
F +44 1902 405 838



Number	97805/01	Replaces	Q96/058
Issued	01/04/2020	Scope	AR 5
Contract number	Q96/058	Page	2-2

## Copper tubes

---

### PRODUCT SPECIFICATION

#### Copper tubes

Half hard dimensions	Soft dimensions	Hard dimensions
12	12	64
15	15	76,1
18	18	88,9
22	22	108
28	28	
35		
42		
54		

---

### APPLICATION AND USE

Copper tubes with or without an external covering for protection of the tube surface and/or as thermal insulation finish coat. The intended use is for 2nd and 3rd family gases in accordance with EN 437 with a maximum operating pressure of 1 bar.

---

### MARKING

- GASTEC QA, GASTEC QA logo or trademark.
  - Manufacturers name or identification mark
  - Date of production: year and quarter or year and month
  - Number of European standard: EN 1057
  - Nominal cross-sectional dimensions: Outside diameter x wall thickness
  - Identification of hardness of the pipe material, R220 or R250 or R290.
  - Type of covering if applicable
- 

### RECOMMENDATIONS FOR END USERS

Check at the time of delivery whether:

- the producer has delivery in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport.

Consult the producer's processing guidelines for the proper storage and transport methods.

Check whether this certificate is still valid by consulting Kiwa Nederland B.V. or the Kiwa website.

If you should reject a product on the basis of the above, please contact the supplier and, if necessary, Kiwa Nederland B.V.

---